

2021 JUN 17 PM 12:46



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION**Consumer Confidence Report (CCR)**

Natchez Water Works, City of Natchez

Public Water System Name

0010002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bills (Attach copy of bill)	5/20/21, 5/28/21, 6/10/21
<input type="checkbox"/> Email message (Email the message to the address below)	
<input checked="" type="checkbox"/> Other By Direct Link on Natchez Water Works Website (www.natchezwaterworks.com)	5/19/2021
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U. S. Postal Mail	
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations)	
<input checked="" type="checkbox"/> Posted online at the following address (Provide Direct URL): http://natchezwaterworks.com/ccr1	5/19/2021

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Jeff Gamberi

Name

Asst. Superintendent

Title

6/17/2021

Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)**Email:** water.reports@msdh.ms.gov

MSDH, Bureau of Public Water Supply

Fax: (601) 576-7800(NOT PREFERRED)

P.O. Box 1700

Jackson, MS 39215

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2020 CONSUMER CONFIDENCE REPORT

Natchez Water Works 2020 Drinking Water Quality Report May 2021

We are very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered over the past year. Our goal is and always has been to provide to you a safe and dependable supply of drinking water. The Natchez Water Works routinely monitors for contaminants in your drinking water according to Federal and State laws. Samples are taken daily to monitor chlorine content, PH levels, and fluoride levels. Samples are taken at various locations throughout the city on a monthly basis that test for the detection of coliform bacteria. Other tests are conducted on a more infrequent basis.

Is my water safe?

Yes. Last year we conducted tests for many contaminants. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. Natchez Water Works is committed to providing you with this information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source is from four wells in the Lower Catahoula Formation Aquifer and one well in the Catahoula Formation Aquifer.

Source water assessment and its availability.

Our source water assessment has been completed. For a report, please contact our office at 601-445-5521.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

How can I get involved?

Please join us for our monthly Board of Water Commissioners meeting on the third Tuesday of each month at 5:15 at our office at 150 N. Shields Lane, Natchez, MS. Please be assured that those of us who work with the Natchez Water Works work hard every day to provide quality drinking water to every customer. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. You may also contact Lance Webb, Water Plant Manager at 601-445-9062.

Additional Information for Fluoride.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", MS0010002 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 100%.

Additional Information for Lead.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Natchez is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

~SEE REVERSE SIDE FOR WATER QUALITY TABLE AND DEFINITIONS~

WATER QUALITY DATA TABLE								
Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
	Low	High						
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl2) (ppm)	4	4	2	1.6	2.4	2020	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	50.3	42.6	50.3	2019	No	By-Product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	43.0	35.0	43.0	2019	No	By-Product of drinking water chlorination
Inorganic Contaminants								
Barium (ppm)	2	2	0,01			2020	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0,903			2020	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	0,21			2020	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (ppm)	NA		130			2019	No	Erosion of natural deposits; Leaching
Chromium (ppb)	100	100	0.6			2020	No	Discharge from steel and pulp mills; Erosion of natural deposits
Radioactive Contaminants								
Alpha emitters (pCi/L)	0	15	3.4			2018	No	Erosion of natural deposits
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper (ppm)	1,3	1,3	0.1	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead (ppb)	0	15	4	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

When samples were not returned by MS State Health Department from 1-1-2020 to 12-31-2020, the most recent test results were used

Unregulated Contaminants

Unregulated Contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

Name	Reported Level	Range		
		Low	High	
HAA6Br (ug/L)	8.61	6.42	10.01	2020
HAA9 (ug/L)	29.91	18.12	40.31	2020
germanium (ug/L)	1.4	1.4	1.4	2020
manganese (ug/L)	13.3	13.3	13.3	2020
bromide (ug/L)	30.6	27.2	32.6	2020

Unit Descriptions	
Term	Definition
ug/L	ug/L: Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (ug/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
Important Drinking Water Definitions	
Term	Definition
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which water system must follow.
Variances and Exceptions	Variances and Exceptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	Maximum Residual Disinfection Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	Monitored not regulated
MPL	State Assigned Maximum Permissible Level

OFFICE HOURS

8:00 AM - 4:00 PM

Monday - Friday

CLOSED

Weekends and Holidays

**Natchez Water Works**

150 N. Shields Lane

Natchez, MS 39120

601-445-5521

www.natchezwaterworks.com

MAILING ADDRESS

PO Box 1325

Natchez, MS 39121

Name on Account		Service Address																														
CN-WATER PLANT		11 CEDAR LANE																														
Account Number	Billing Cycle	Service Period	Bill Date	Due Date																												
16519	2	03/30/2021 - 04/29/2021	05/20/2021	06/05/2021																												
Service Description	Present Reading	Consumption (Cu. Ft.)	Amount																													
BALANCE FORWARD			\$301.04																													
WATER	21323	191	\$21.45																													
SEWER	21323	191	\$21.45																													
NO OTHER NOTICE WILL BE SENT			Total Amount Due Now	\$343.94																												
ACCOUNT PAST DUE			Pay This Amount After Due Date	\$343.94																												
SERVICE WILL BE DISCONNECTED ON 06/05/2021																																
<p>SHOULD YOUR BILL REFLECT A BALANCE FORWARD, PAYMENT OF THE BALANCE FORWARD IS DUE IMMEDIATELY. FAILURE TO PAY THE BALANCE FORWARD MAY RESULT IN DISCONNECTION OF SERVICE. PAYMENTS MADE BY PHONE OR WEB WILL NOT BE PROCESSED UNTIL THE NEXT BUSINESS DAY. FAILURE TO RECEIVE A BILL DOES NOT RELEASE CUSTOMER FROM OBLIGATION TO PAY.</p>																																
<p>Payment Options</p> <ul style="list-style-type: none"> - By Bank Draft - By Mail - Drop Box - By Phone Call: 844-382-4429 or 601-445-5521 Option #3 - Drive Thru Window - In person at Main Office - www.natchezwaterworks.com 																																
<p>Consumption (Cu. Ft.) - Last 13 Months</p> <table border="1"> <caption>Consumption (Cu. Ft.) - Last 13 Months</caption> <thead> <tr> <th>Month</th> <th>Consumption (Cu. Ft.)</th> </tr> </thead> <tbody> <tr><td>May</td><td>219</td></tr> <tr><td>Jun</td><td>191</td></tr> <tr><td>Jul</td><td>328</td></tr> <tr><td>Aug</td><td>328</td></tr> <tr><td>Sep</td><td>219</td></tr> <tr><td>Oct</td><td>219</td></tr> <tr><td>Nov</td><td>191</td></tr> <tr><td>Dec</td><td>191</td></tr> <tr><td>Jan</td><td>219</td></tr> <tr><td>Feb</td><td>328</td></tr> <tr><td>Mar</td><td>219</td></tr> <tr><td>Apr</td><td>191</td></tr> <tr><td>Cur</td><td>191</td></tr> </tbody> </table>					Month	Consumption (Cu. Ft.)	May	219	Jun	191	Jul	328	Aug	328	Sep	219	Oct	219	Nov	191	Dec	191	Jan	219	Feb	328	Mar	219	Apr	191	Cur	191
Month	Consumption (Cu. Ft.)																															
May	219																															
Jun	191																															
Jul	328																															
Aug	328																															
Sep	219																															
Oct	219																															
Nov	191																															
Dec	191																															
Jan	219																															
Feb	328																															
Mar	219																															
Apr	191																															
Cur	191																															
<p>Important information about your drinking water is available in the 2020 Consumer Confidence Report at https://natchezwaterworks.com/ccr1. To request a hard copy check this box <input type="checkbox"/> or call our office, (601)445-5521</p>																																

Please bring entire bill if paying in person or at Drive-Thru

Please detach and return bottom portion if paying by mail

MS28139F

**NATCHEZ WATER WORKS**

PO BOX 1325

NATCHEZ MS 39121-1325

Return Service Requested

☐ Check box here to update your mailing address or other important information regarding your account by completing the form on the back and returning to us.

Account Number	16519
Total Amount Due Now	\$343.94
Due Date	06/05/2021
Pay This Amount After Due Date	\$343.94
Please Enter Amount Paid	



CN-WATER PLANT
ATTN: DIANNE GUILLORY
PO BOX 1325
NATCHEZ MS 39121-1325

0
12

NATCHEZ WATER WORKS
PO BOX 1325
NATCHEZ MS 39121-1325



OFFICE HOURS
8:00 AM - 4:00 PM
Monday - Friday
CLOSED
Weekends and Holidays



Natchez Water Works

150 N. Shields Lane
Natchez, MS 39120
601-445-5521
www.natchezwaterworks.com

MAILING ADDRESS
PO Box 1325
Natchez, MS 39121

Name on Account		Service Address		
CN-WATER WORKS		150 SHIELDS LN		
Account Number	Billing Cycle	Service Period	Bill Date	Due Date
631	M	04/07/2021 - 05/10/2021	05/28/2021	06/15/2021
Service Description	Present Reading	Consumption (Cu. Ft.)	Amount	
BALANCE FORWARD			\$294.76	
WATER	10260	599	\$20.70	
SEWER	10260	599	\$20.70	
NO OTHER NOTICE WILL BE SENT			Total Amount Due Now	\$336.16
ACCOUNT PAST DUE			Pay This Amount After Due Date	\$336.16
SERVICE WILL BE DISCONNECTED ON 06/15/2021				
<p>SHOULD YOUR BILL REFLECT A BALANCE FORWARD, PAYMENT OF THE BALANCE FORWARD IS DUE IMMEDIATELY. FAILURE TO PAY THE BALANCE FORWARD MAY RESULT IN DISCONNECTION OF SERVICE. PAYMENTS MADE BY PHONE OR WEB WILL NOT BE PROCESSED UNTIL THE NEXT BUSINESS DAY. FAILURE TO RECEIVE A BILL DOES NOT RELEASE CUSTOMER FROM OBLIGATION TO PAY.</p>				
<p>Payment Options</p> <ul style="list-style-type: none"> - By Bank Draft - By Mail - Drop Box - By Phone Call: 844-382-4429 or 601-445-5521 Option #3 - Drive Thru Window - In person at Main Office - www.natchezwaterworks.com 				
<p>Consumption (Cu. Ft.) - Last 13 Months</p>				
<p>Important information about your drinking water is available in the 2020 Consumer Confidence Report at https://natchezwaterworks.com/ccr1. To request a hard copy check this box <input type="checkbox"/> or call our office, (601)445-5521.</p>				

Please bring entire bill if paying in person or at Drive-Thru

Please detach and return bottom portion if paying by mail

MS28139F



NATCHEZ WATER WORKS
PO BOX 1325
NATCHEZ MS 39121-1325
Return Service Requested

☐ Check box here to update your mailing address or other important information regarding your account by completing the form on the back and returning to us.

*****AUTO**5-DIGIT 39120



CN-WATER WORKS
ATTN: DIANNE GUILLORY
PO BOX 1325
NATCHEZ MS 39121-1325

8
2066



Account Number	631
Total Amount Due Now	\$336.16
Due Date	06/15/2021
Pay This Amount After Due Date	\$336.16
Please Enter Amount Paid	

NATCHEZ WATER WORKS
PO BOX 1325
NATCHEZ MS 39121-1325



OFFICE HOURS

8:00 AM - 4:00 PM

Monday - Friday

CLOSED

Weekends and Holidays

**Natchez Water Works**

150 N. Shields Lane

Natchez, MS 39120

601-445-5521

www.natchezwaterworks.com

MAILING ADDRESS

PO Box 1325

Natchez, MS 39121

Name on Account		Service Address																														
CN-WATER WORKS MAINTENANCE SHOP		150 SHIELDS LN																														
Account Number	Billing Cycle	Service Period	Bill Date	Due Date																												
16531	1	04/20/2021 - 05/18/2021	06/10/2021	06/25/2021																												
Service Description	Present Reading	Consumption (Cu. Ft.)	Amount																													
BALANCE FORWARD																																
			\$715.60																													
WATER	147641	899	\$36.19																													
SEWER	147641	899	\$36.19																													
NO OTHER NOTICE WILL BE SENT			Total Amount Due Now																													
			\$787.98																													
ACCOUNT PAST DUE			Pay This Amount After Due Date																													
SERVICE WILL BE DISCONNECTED ON 06/25/2021			\$787.98																													
<p>SHOULD YOUR BILL REFLECT A BALANCE FORWARD, PAYMENT OF THE BALANCE FORWARD IS DUE IMMEDIATELY. FAILURE TO PAY THE BALANCE FORWARD MAY RESULT IN DISCONNECTION OF SERVICE. PAYMENTS MADE BY PHONE OR WEB WILL NOT BE PROCESSED UNTIL THE NEXT BUSINESS DAY. FAILURE TO RECEIVE A BILL DOES NOT RELEASE CUSTOMER FROM OBLIGATION TO PAY.</p>																																
<p>Payment Options</p> <ul style="list-style-type: none"> - By Bank Draft - By Mail - Drop Box - By Phone Call: 844-382-4429 or 601-445-5521 Option #3 - Drive Thru Window - In person at Main Office - www.natchezwaterworks.com 																																
<p>Consumption (Cu. Ft.) - Last 13 Months</p> <table border="1"> <caption>Consumption (Cu. Ft.) - Last 13 Months</caption> <thead> <tr> <th>Month</th> <th>Consumption (Cu. Ft.)</th> </tr> </thead> <tbody> <tr><td>Jun</td><td>1360</td></tr> <tr><td>Jul</td><td>1360</td></tr> <tr><td>Aug</td><td>4080</td></tr> <tr><td>Sep</td><td>1360</td></tr> <tr><td>Oct</td><td>1360</td></tr> <tr><td>Nov</td><td>1360</td></tr> <tr><td>Dec</td><td>1360</td></tr> <tr><td>Jan</td><td>1360</td></tr> <tr><td>Feb</td><td>1360</td></tr> <tr><td>Mar</td><td>1360</td></tr> <tr><td>Apr</td><td>1360</td></tr> <tr><td>May</td><td>1360</td></tr> <tr><td>Cur</td><td>1360</td></tr> </tbody> </table>					Month	Consumption (Cu. Ft.)	Jun	1360	Jul	1360	Aug	4080	Sep	1360	Oct	1360	Nov	1360	Dec	1360	Jan	1360	Feb	1360	Mar	1360	Apr	1360	May	1360	Cur	1360
Month	Consumption (Cu. Ft.)																															
Jun	1360																															
Jul	1360																															
Aug	4080																															
Sep	1360																															
Oct	1360																															
Nov	1360																															
Dec	1360																															
Jan	1360																															
Feb	1360																															
Mar	1360																															
Apr	1360																															
May	1360																															
Cur	1360																															
<p>Important information about your drinking water is available in the 2020 Consumer Confidence Report at https://natchezwaterworks.com/ccr1. To request a hard copy, check this box <input type="checkbox"/> or call our office, (601)445-5521.</p>																																

For Electronic Delivery of your Bill, go to www.NatchezWaterWorks.com. To Enroll, you will need your account number and temporary password, 000738256742.

Please bring entire bill if paying in person or at Drive-Thru

Please detach and return bottom portion if paying by mail

MS28139F



NATCHEZ WATER WORKS
PO BOX 1325
NATCHEZ MS 39121-1325
Return Service Requested

☐ Check box here to update your mailing address or other important information regarding your account by completing the form on the back and returning to us.

Account Number	16531
Total Amount Due Now	\$787.98
Due Date	06/25/2021
Pay This Amount After Due Date	\$787.98
Please Enter Amount Paid	



CN-WATER WORKS MAINTENANCE SHOP 0
ATTN: DIANNE GUILLORY 14
PO BOX 1325
NATCHEZ MS 39121-1325

NATCHEZ WATER WORKS
PO BOX 1325
NATCHEZ MS 39121-1325

